



MILLIGAN
Water Supply Corporation

2026 CONSUMER CONFIDENCE REPORT



Annual Water Quality Report
for Reporting Year 2025



Annual Drinking Water Quality Report

MILLIGAN WSC

Public Water System ID: TX0430041

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. (Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono 972-542-1143.

For more information regarding this report, contact:

Name: Candi Blisard

Phone: 972-542-1143

Sources of Drinking Water

MILLIGAN WSC is Purchased surface water.

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
SW FROM NORTH TEXAS MWD	CC FROM TX0430044 NORTH TEXAS MWD	Surface water	Completed	tceq.texas.gov/gis/swaview

SOURCE WATER ASSESSMENTS • The NTMWD Wylie Water Treatment Plants have met all of the requirements for participation in the TCEQ Source Water Protection Program (SWPP). This is a voluntary program that helps public water systems like NTMWD protect our drinking water sources and ensure its continued reliability. Participating in the SWPP helps us identify, assess and manage potential sources of contamination to Lavon Lake and strengthens our commitment to protecting the quality of our source waters against potential pollutants. For more information on source water assessments and protection efforts at the Wylie and Tawakoni Water Treatment Plant systems, visit NTMWD.com/watershed for more information. For more about the sources of your water, please refer to the Source Water Assessment Viewer available at tceq.texas.gov/gis/swaview. Further details about sources and source-water assessments are also available via Drinking Water Watch at www.tceq.texas.gov/drinkingwater/SWAP.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. MILLIGAN WSC is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact MILLIGAN WSC at 972-542-1143. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Milligan Water Supply Corporation has completed and submitted its Lead Service Line Inventory as required by EPA and TCEQ regulations. A copy of the inventory is available by calling 972-542-1143 or visiting www.milliganwater.com

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Milligan Water Supply Corporation Board of Directors meetings are held monthly, typically held second Wednesday of the month at the Milligan WSC Office, 1400 S. Bridgefarmer Road, McKinney, Texas 75069. The public is welcome to attend. Please call 972-542-1143 to confirm the date and time.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Chloramines	2025	2.7	ppm	1.7 – 3.7	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2025	0.599	0.00405 - 1.14	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2025	0.861	0 - 7.11	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	1373 OLD MILL RD, MCKINNEY	2025	14	9.4 - 22	ppb	60	0	By-product of drinking water disinfection
TTHM	1373 OLD MILL RD, MCKINNEY	2025	23	11.2 - 40.3	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
DIBROMOCHLOROMETHANE	10/13/2025	13.8	3.81 - 13.8	UG/L	0	0.06	
NITRATE	5/7/2025	0.243	0.243	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	5/13/2020	0.4	0.4	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

There are no additional required health effects notices.

There are no additional required health effects violation notices.

The following pages provided by our water supplier North Texas Municipal Water District.

North Texas Municipal Water District

Wylie Water Treatment Plants - Water Quality Data for Year 2025

NTMWD Wylie Water Treatment Plants Water Quality Data for Year 2025

Coliform Bacteria								
Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level		Highest No. of Positive	Fecal Coliform or E. Coli Maximum C ontaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples		Violation	Likely Source of Contamination
0	1 positive monthly sample		0	0	0		No	Naturally present in the environment.

NOTE: Reported monthly tests found no fecal coliform bacteria. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other,

potentially harmful bacteria may be present.

Regulated Contaminants

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Antimony	2025	Levels lower than detect level	0 - 0	6	6	ppb	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; and test addition.
Arsenic	2025	1	1 - 1	0	10	ppb	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	2025	0.055	0.038 - 0.055	2	2	ppm	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Beryllium	2025	Levels lower than detect level	0 - 0	4	4	ppb	No	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
Cadmium	2025	Levels lower than detect level	0 - 0	5	5	ppb	No	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
Chromium	2025	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from steel and pulp mills; erosion of natural deposits.
Cyanide	2025	56	47.0 - 56.0	0 - 0	200	ppb	No	Discharge from steel/metal factories; Discharge from plastics and fertilizer factories.
Fluoride	2025	0.492	0.352 - 0.492	4	4	ppm	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Mercury	2025	Levels lower than detect level	0 - 0	2	2	ppb	No	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
Nitrate (measured as Nitrogen)	2025	0.866	0.082 - 0.866	10	10	ppm	No	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
Selenium	2025	Levels lower than detect level	0 - 0	50	50	ppb	No	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Thallium	2025	Levels lower than detect level	0 - 0	0.5	2	ppb	No	Discharge from electronics, glass, and leaching from ore-processing sites; drug factories.

Nitrate Advisory: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue

baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2024	5.3	5.3 - 5.3	0	50	pCi/L	No	Decay of natural and man-made deposits.
Gross alpha excluding radon and uranium	2024	Levels lower than detect level	0 - 0	0	15	pCi/L	No	Erosion of natural deposits.
Radium	2024	Levels lower than detect level	0 - 0	0	5	pCi/L	No	Erosion of natural deposits.

NTMWD Wylie Water Treatment Plants Water Quality Data for Year 2025 (Cont.)

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
--	-----------------	------------------------	--------------------------	------	-----	-------	-----------	--------------------------------

2, 4, 5 - TP (Silvex)	2025	Levels lower than detect level	0 - 0	50	50	ppb	No	Residue of banned herbicide.
2, 4 - D	2025	Levels lower than detect level	0 - 0	70	70	ppb	No	Runoff from herbicide used on row crops.
Alachlor	2025	Levels lower than detect level	0 - 0	0	2	ppb	No	Runoff from herbicide used on row crops.
Aldicarb	2025	Levels lower than detect level	0 - 0	1	3	ppb	No	Runoff from agricultural pesticide.
Aldicarb Sulfone	2025	Levels lower than detect level	0 - 0	1	2	ppb	No	Runoff from agricultural pesticide.
Aldicarb Sulfoxide	2025	Levels lower than detect level	0 - 0	1	4	ppb	No	Runoff from agricultural pesticide.
Atrazine	2025	0.1	0.1 - 0.1	3	3	ppb	No	Runoff from herbicide used on row crops.
Benzo (a) pyrene	2025	Levels lower than detect level	0 - 0	0	200	ppt	No	Leaching from linings of water storage tanks and distribution lines.
Carbofuran	2025	Levels lower than detect level	0 - 0	40	40	ppb	No	Leaching of soil fumigant used on rice and alfalfa.
Chlordane	2025	Levels lower than detect level	0 - 0	0	2	ppb	No	Residue of banned termiticide.
Dalapon	2025	Levels lower than detect level	0 - 0	200	200	ppb	No	Runoff from herbicide used on rights of way.
Di (2-ethylhexyl) adipate	2025	Levels lower than detect level	0 - 0	400	400	ppb	No	Discharge from chemical factories.
Di (2-ethylhexyl) phthalate	2025	Levels lower than detect level	0 - 0	0	6	ppb	No	Discharge from rubber and chemical factories.
Dibromochloropropane (DBCP)	2025	Levels lower than detect level	0 - 0	0	200	ppt	No	Runoff / leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards.
Dinoseb	2025	Levels lower than detect level	0 - 0	7	7	ppb	No	Runoff from herbicide used on soybeans and vegetables.
Endrin	2025	Levels lower than detect level	0 - 0	2	2	ppb	No	Residue of banned insecticide.
Ethylene dibromide	2025	Levels lower than detect level	0 - 0	0	50	ppt	No	Discharge from petroleum refineries.
Heptachlor	2025	Levels lower than detect level	0 - 0	0	400	ppt	No	Residue of banned termiticide.
Heptachlor epoxide	2025	Levels lower than detect level	0 - 0	0	200	ppt	No	Breakdown of heptachlor.
Hexachlorobenzene	2025	Levels lower than detect level	0 - 0	0	1	ppb	No	Discharge from metal refineries and agricultural chemical factories.
Hexachlorocyclopentadiene	2025	Levels lower than detect level	0 - 0	50	50	ppb	No	Discharge from chemical factories.
Lindane	2025	Levels lower than detect level	0 - 0	200	200	ppt	No	Runoff / leaching from insecticide used on cattle, lumber, and gardens.
Methoxychlor	2025	Levels lower than detect level	0 - 0	40	40	ppb	No	Runoff / leaching from insecticide used on fruits, vegetables, alfalfa, and livestock.
Oxamyl [Vydate]	2025	Levels lower than detect level	0 - 0	200	200	ppb	No	Runoff / leaching from insecticide used on apples, potatoes, and tomatoes.
Pentachlorophenol	2025	Levels lower than detect level	0 - 0	0	1	ppb	No	Discharge from wood preserving factories.
Picloram	2025	Levels lower than detect level	0 - 0	500	500	ppb	No	Herbicide runoff.
Simazine	2025	Levels lower than detect level	0 - 0	4	4	ppb	No	Herbicide runoff.
Toxaphene	2025	Levels lower than detect level	0 - 0	0	3	ppb	No	Runoff / leaching from insecticide used on cotton and cattle.
Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
1, 1, 1 - Trichloroethane	2025	Levels lower than detect level	0 - 0	200	200	ppb	No	Discharge from metal degreasing sites and other factories.
1, 1, 2 - Trichloroethane	2025	Levels lower than detect level	0 - 0	3	5	ppb	No	Discharge from industrial chemical factories.
1, 1 - Dichloroethylene	2025	Levels lower than detect level	0 - 0	7	7	ppb	No	Discharge from industrial chemical factories.

1, 2, 4 - Trichlorobenzene	2025	Levels lower than detect level	0 - 0	70	70	ppb	No	Discharge from textile-finishing factories.
1, 2 - Dichloroethane	2025	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from industrial chemical factories.
1, 2 - Dichloropropane	2025	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from industrial chemical factories.
Benzene	2025	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from factories; leaching from gas storage tanks and landfills.
Carbon Tetrachloride	2025	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from chemical plants and other industrial activities.

**NTMWD Wylie Water Treatment Plants
Water Quality Data for Year 2025 (Cont.)**

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorobenzene	2025	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from chemical and agricultural chemical factories.
Dichloromethane	2025	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from pharmaceutical and chemical factories.
Ethylbenzene	2025	Levels lower than detect level	0 - 0	0	700	ppb	No	Discharge from petroleum refineries.
Styrene	2025	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from rubber and plastic factories; leaching from landfills.
Tetrachloroethylene	2025	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from factories and dry cleaners.
Toluene	2025	Levels lower than detect level	0 - 0	1	1	ppm	No	Discharge from petroleum factories.
Trichloroethylene	2025	Levels lower than detect level	0 - 0	0	5	ppb	No	Discharge from metal degreasing sites and other factories.
Vinyl Chloride	2025	Levels lower than detect level	0 - 0	0	2	ppb	No	Leaching from PVC piping; discharge from plastics factories.
Xylenes	2025	Levels lower than detect level	0 - 0	10	10	ppm	No	Discharge from petroleum factories; discharge from chemical factories.
cis - 1, 2 - Dichloroethylene	2025	Levels lower than detect level	0 - 0	70	70	ppb	No	Discharge from industrial chemical factories.
o - Dichlorobenzene	2025	Levels lower than detect level	0 - 0	600	600	ppb	No	Discharge from industrial chemical factories.
p - Dichlorobenzene	2025	Levels lower than detect level	0 - 0	75	75	ppb	No	Discharge from industrial chemical factories.
trans - 1, 2 - Dichloroethylene	2025	Levels lower than detect level	0 - 0	100	100	ppb	No	Discharge from industrial chemical factories.

Turbidity

			Limit (Treatment Technique)		Level Detected		Violation	Likely Source of Contamination
Highest single measurement			1 NTU		0.29		No	Soil runoff.
Lowest monthly percentage (%) meeting limit			0.3 NTU		1		No	Soil runoff.

NOTE: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness

of our filtration.

--	--	--	--	--	--	--	--	--

Total Organic Carbon

--	--	--	--	--	--	--	--	--

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set.

--	--	--	--	--	--	--	--	--

Cryptosporidium and Giardia

Contaminants	Collection Date	Highest Level Detected		Range of Levels Detected		Units		Likely Source of Contamination
Cryptosporidium	2025	Levels lower than detect level		0 - 0		(Oo) Cysts/L		Human and animal fecal waste. Naturally present in the environment.

Giardia	2025	Levels lower than detect level		0 - 0		(Oo) Cysts/L		Human and animal fecal waste. Naturally present in the environment.
NOTE: Levels detected are for source water, not for drinking water. No cryptosporidium or giardia were found in drinking water.								
NTMWD Wylie Water Treatment Plants Water Quality Data for Year 2025 (Cont.)								
Unregulated Contaminants								
Contaminants	Collection Date	Highest Level Detected		Range of Levels Detected		Units		Likely Source of Contamination
Chloroform	2025	18.5		16.3-18.5		ppb		By-product of drinking water disinfection.
Bromoform	2025	2.46		2.24-2.46		ppb		By-product of drinking water disinfection.
Bromodichloromethane	2025	20		17.5-20		ppb		By-product of drinking water disinfection.
Dibromochloromethane	2025	15.3		13.1-15.3		ppb		By-product of drinking water disinfection.
NOTE: Bromoform, chloroform, bromodichloromethane, and dibromochloromethane are disinfection by-products. There is no maximum contaminant level for these chemicals at the entry point to distribution. These contaminants are included in the Disinfection By-Products TTHM compliance data.								
Secondary and Other Constituents Not Regulated								
Contaminants	Collection Date	Highest Level Detected		Range of Levels Detected		Units		Likely Source of Contamination
Aluminum	2025	Levels lower than detect level		0 - 0		ppm		Erosion of natural deposits.
Calcium	2025	61.3		31.2 - 61.3		ppm		Abundant naturally occurring element.
Chloride	2025	92.5		29.0 - 92.5		ppm		Abundant naturally occurring element; used in water purification; by-product of oil field activity.
Iron	2025	Levels lower than detect level		0 - 0		ppm		Erosion of natural deposits; iron or steel water delivery equipment or facilities.
Magnesium	2025	9.44		6.27 - 9.44		ppm		Abundant naturally occurring element.
Manganese	2025	0.002		0.002 - 0.002		ppm		Abundant naturally occurring element.
Nickel	2025	0.007		0.005 - 0.007		ppm		Erosion of natural deposits.
pH	2025	8.8		7.3 - 8.8		units		Measure of corrosivity of water.
Silver	2025	Levels lower than detect level		0 - 0		ppm		Erosion of natural deposits.
Sodium	2025	88.0		41.9 - 88.0		ppm		Erosion of natural deposits; by-product of oil field activity.
Sulfate	2025	147		84.7 - 147		ppm		Naturally occurring; common industrial by-product; by-product of oil field activity.
Total Alkalinity as CaCO3	2025	138		43.6 - 138		ppm		Naturally occurring soluble mineral salts.
Total Dissolved Solids	2025	455		182 - 455		ppm		Total dissolved mineral constituents in water.
Total Hardness as CaCO3	2025	200		96.0 - 200		ppm		Naturally occurring calcium.
Zinc	2025	0.016		0.006 - 0.016		ppm		Moderately abundant naturally occurring element used in the metal industry.
Lead Service Line Inventory								
North Texas Municipal Water District has completed its service line inventory and determined through field investigations that no lead, galvanized requiring replacement, or lead status unknown service lines are in the system. To view and access the service line inventory, go to https://www.ntmwd.com/200/Water-Quality .								